

Change to Zoning Ordinance

Section 9.1.3.3 F.d. The area beneath the ground floor of the structure shall be enclosed around the exterior of the structure with a non-load bearing curtain wall constructed of masonry block, brick, or stone finish, at least 4 inches thick, or metal or molded curtain walls penetrated by openings only for installed vents and access doors. Vinyl curtain walls are not allowed. When metal or molded curtain walls are used they must be attached to treated wood framing that is no more than 24 inch on center or metal channel framing. The wood or metal framing will be securely anchored at the top and bottom.

This was approved and adopted by the Madison County Board of Commissioners on June 23, 2008.

Wesley Nash, Chairman

Morris Fortson, County Clerk