

Section 10.4 Well and Well Lots. All municipal and public potable water wells must:

1. Meet the Georgia Environmental Protection Division's wellhead protection requirements; and
2. Be separately platted and so identified on preliminary and final plats; and
3. Have no structure closer than twenty (20) feet to a common property line or right-of-way; and
4. Have no structure closer than one thousand (1000) feet to an oil or gas pipeline unless one of the following two conditions is met;
  - a. The development is served by a public water system; or
  - b. Monitoring wells drilled on the property prior to preliminary plat approval show no contamination of the site by liquid petroleum or natural gas products. Water samples from monitoring wells shall be collected routinely at permit-specified time intervals, and analyzed by the Georgia Environmental Protection Division (EPD) or state approved independent laboratories.

This was approved and adopted on February 25, 2008 by the Madison County Board of Commissioners.

---

Wesley Nash, Chairman

---

Morris Fortson, County Clerk